

令和6年(2024)1月31日

令和4年度 札幌市水道 水量水質年報におきまして、内容の一部に誤りがございましたので、下記のとおり訂正いたしました

記

ページ	項目	(誤)	(正)
p 58	1 2 薬品使用量 総計値 (札幌水道)	別紙1のとおり	
p 58	1 2 薬品使用量 総計値 (札幌水道)	別紙2のとおり	
p 59	1 2 薬品使用量 白川浄水場	別紙3のとおり	
p 62	1 3 ろ過池使用状況 白川浄水場	別紙4のとおり	
p 215	1 浄水場給水区域図	別紙5のとおり	
p 216	2 給水区域図及び施設位置図		
p 217	3 配水系統図	別紙6のとおり	

以上

(誤)	総計値（札幌水道）				
	項目 年月	ポリ塩化アルミニウム		消石灰	
		使用量 kg	注入率 g/m ³	使用量 kg	注入率 g/m ³
	令和4年 4月	492,060	31.0	43,755	2.8
	5月	404,315	24.7	33,847	2.1
	6月	375,442	23.6	28,435	1.8
	7月	413,118	24.7	27,175	1.7
	8月	699,980	42.7	52,816	3.3
	9月	504,251	32.0	27,460	1.8
	10月	515,710	31.6	24,607	1.5
	11月	492,123	31.5	26,384	1.7
	12月	326,783	19.9	14,815	0.9
	令和5年 1月	395,930	24.4	25,790	1.6
	2月	276,186	18.5	19,541	1.3
3月	422,524	25.9	31,748	2.0	
合計	5,318,422		356,373		
月平均	443,202	27.6	29,698	1.9	
日平均	14,571		976		

(正)	総計値（札幌水道）				
	項目 年月	ポリ塩化アルミニウム		消石灰	
		使用量 kg	注入率 g/m ³	使用量 kg	注入率 g/m ³
	令和4年 4月	492,060	30.7	43,755	2.8
	5月	404,315	24.5	33,847	2.1
	6月	375,442	23.4	28,435	1.8
	7月	413,118	24.5	27,175	1.6
	8月	699,980	42.3	52,816	3.3
	9月	504,251	31.8	27,460	1.8
	10月	515,710	31.3	24,607	1.5
	11月	492,123	31.2	26,384	1.7
	12月	326,783	19.8	14,815	0.9
	令和5年 1月	395,930	24.1	25,790	1.6
	2月	276,186	18.3	19,541	1.3
3月	422,524	25.5	28,086	1.7	
合計	5,318,422		352,711		
月平均	443,202	27.3	29,393	1.8	
日平均	14,571		966		

備考	p.58 1 2 薬品使用量 総計値（札幌水道）
----	--------------------------

(誤)	<table border="1"> <thead> <tr> <th rowspan="2">項目 年月</th> <th colspan="2">ソーダ灰</th> <th colspan="2">次亜塩素酸ナトリウム</th> <th>活性炭</th> </tr> <tr> <th>使用量 kg</th> <th>注入率 g/m³</th> <th>使用量 kg</th> <th>注入率 g/m³</th> <th>使用量 kg</th> </tr> </thead> <tbody> <tr><td>令和4年 4月</td><td>2,155</td><td>7.9</td><td>115,182</td><td>3.8</td><td>1,537</td></tr> <tr><td>5月</td><td>1,688</td><td>5.7</td><td>106,015</td><td>3.3</td><td>5</td></tr> <tr><td>6月</td><td>1,011</td><td>3.6</td><td>125,330</td><td>4.0</td><td>8,647</td></tr> <tr><td>7月</td><td>1,150</td><td>3.9</td><td>172,945</td><td>5.2</td><td>2,944</td></tr> <tr><td>8月</td><td>1,896</td><td>6.4</td><td>167,435</td><td>5.2</td><td>26,089</td></tr> <tr><td>9月</td><td>938</td><td>3.3</td><td>166,001</td><td>5.3</td><td>1,511</td></tr> <tr><td>10月</td><td>1,512</td><td>4.4</td><td>172,122</td><td>7.3</td><td>5,382</td></tr> <tr><td>11月</td><td>917</td><td>3.0</td><td>152,417</td><td>5.9</td><td>14,938</td></tr> <tr><td>12月</td><td>770</td><td>2.6</td><td>132,315</td><td>4.1</td><td>1,018</td></tr> <tr><td>令和5年 1月</td><td>507</td><td>1.7</td><td>142,464</td><td>4.5</td><td>48,098</td></tr> <tr><td>2月</td><td>406</td><td>1.5</td><td>114,553</td><td>3.8</td><td>8,714</td></tr> <tr><td>3月</td><td>2,573</td><td>7.6</td><td>120,515</td><td>3.7</td><td>6,098</td></tr> <tr><td>合計</td><td>15,520</td><td></td><td>1,687,295</td><td></td><td>124,981</td></tr> <tr><td>月平均</td><td>1,293</td><td rowspan="2">4.7</td><td>140,608</td><td rowspan="2">0.9</td><td>10,415</td></tr> <tr><td>日平均</td><td>43</td><td>4,623</td><td>342</td></tr> </tbody> </table>						項目 年月	ソーダ灰		次亜塩素酸ナトリウム		活性炭	使用量 kg	注入率 g/m ³	使用量 kg	注入率 g/m ³	使用量 kg	令和4年 4月	2,155	7.9	115,182	3.8	1,537	5月	1,688	5.7	106,015	3.3	5	6月	1,011	3.6	125,330	4.0	8,647	7月	1,150	3.9	172,945	5.2	2,944	8月	1,896	6.4	167,435	5.2	26,089	9月	938	3.3	166,001	5.3	1,511	10月	1,512	4.4	172,122	7.3	5,382	11月	917	3.0	152,417	5.9	14,938	12月	770	2.6	132,315	4.1	1,018	令和5年 1月	507	1.7	142,464	4.5	48,098	2月	406	1.5	114,553	3.8	8,714	3月	2,573	7.6	120,515	3.7	6,098	合計	15,520		1,687,295		124,981	月平均	1,293	4.7	140,608	0.9	10,415	日平均	43	4,623	342
	項目 年月	ソーダ灰		次亜塩素酸ナトリウム		活性炭																																																																																																			
		使用量 kg	注入率 g/m ³	使用量 kg	注入率 g/m ³	使用量 kg																																																																																																			
	令和4年 4月	2,155	7.9	115,182	3.8	1,537																																																																																																			
	5月	1,688	5.7	106,015	3.3	5																																																																																																			
	6月	1,011	3.6	125,330	4.0	8,647																																																																																																			
	7月	1,150	3.9	172,945	5.2	2,944																																																																																																			
	8月	1,896	6.4	167,435	5.2	26,089																																																																																																			
	9月	938	3.3	166,001	5.3	1,511																																																																																																			
	10月	1,512	4.4	172,122	7.3	5,382																																																																																																			
	11月	917	3.0	152,417	5.9	14,938																																																																																																			
	12月	770	2.6	132,315	4.1	1,018																																																																																																			
	令和5年 1月	507	1.7	142,464	4.5	48,098																																																																																																			
	2月	406	1.5	114,553	3.8	8,714																																																																																																			
3月	2,573	7.6	120,515	3.7	6,098																																																																																																				
合計	15,520		1,687,295		124,981																																																																																																				
月平均	1,293	4.7	140,608	0.9	10,415																																																																																																				
日平均	43		4,623		342																																																																																																				
(正)	<table border="1"> <thead> <tr> <th rowspan="2">項目 年月</th> <th colspan="2">ソーダ灰</th> <th colspan="2">次亜塩素酸ナトリウム</th> <th>活性炭</th> </tr> <tr> <th>使用量 kg</th> <th>注入率 g/m³</th> <th>使用量 kg</th> <th>注入率 g/m³</th> <th>使用量 kg</th> </tr> </thead> <tbody> <tr><td>令和4年 4月</td><td>2,155</td><td>7.9</td><td>115,182</td><td>0.8</td><td>1,537</td></tr> <tr><td>5月</td><td>1,688</td><td>5.7</td><td>106,015</td><td>0.7</td><td>5</td></tr> <tr><td>6月</td><td>1,011</td><td>3.6</td><td>125,330</td><td>0.9</td><td>8,647</td></tr> <tr><td>7月</td><td>1,150</td><td>3.9</td><td>172,945</td><td>1.1</td><td>2,944</td></tr> <tr><td>8月</td><td>1,896</td><td>6.4</td><td>167,435</td><td>1.1</td><td>26,089</td></tr> <tr><td>9月</td><td>938</td><td>3.3</td><td>166,001</td><td>1.1</td><td>1,511</td></tr> <tr><td>10月</td><td>1,512</td><td>4.4</td><td>172,122</td><td>1.2</td><td>5,382</td></tr> <tr><td>11月</td><td>917</td><td>3.0</td><td>152,417</td><td>1.1</td><td>14,938</td></tr> <tr><td>12月</td><td>770</td><td>2.6</td><td>132,315</td><td>0.9</td><td>1,018</td></tr> <tr><td>令和5年 1月</td><td>507</td><td>1.7</td><td>142,464</td><td>1.0</td><td>48,098</td></tr> <tr><td>2月</td><td>406</td><td>1.5</td><td>114,553</td><td>0.8</td><td>8,714</td></tr> <tr><td>3月</td><td>2,573</td><td>7.6</td><td>120,515</td><td>0.8</td><td>6,098</td></tr> <tr><td>合計</td><td>15,520</td><td></td><td>1,687,295</td><td></td><td>124,981</td></tr> <tr><td>月平均</td><td>1,293</td><td rowspan="2">4.7</td><td>140,608</td><td rowspan="2">0.9</td><td>10,415</td></tr> <tr><td>日平均</td><td>43</td><td>4,623</td><td>342</td></tr> </tbody> </table>						項目 年月	ソーダ灰		次亜塩素酸ナトリウム		活性炭	使用量 kg	注入率 g/m ³	使用量 kg	注入率 g/m ³	使用量 kg	令和4年 4月	2,155	7.9	115,182	0.8	1,537	5月	1,688	5.7	106,015	0.7	5	6月	1,011	3.6	125,330	0.9	8,647	7月	1,150	3.9	172,945	1.1	2,944	8月	1,896	6.4	167,435	1.1	26,089	9月	938	3.3	166,001	1.1	1,511	10月	1,512	4.4	172,122	1.2	5,382	11月	917	3.0	152,417	1.1	14,938	12月	770	2.6	132,315	0.9	1,018	令和5年 1月	507	1.7	142,464	1.0	48,098	2月	406	1.5	114,553	0.8	8,714	3月	2,573	7.6	120,515	0.8	6,098	合計	15,520		1,687,295		124,981	月平均	1,293	4.7	140,608	0.9	10,415	日平均	43	4,623	342
	項目 年月	ソーダ灰		次亜塩素酸ナトリウム		活性炭																																																																																																			
		使用量 kg	注入率 g/m ³	使用量 kg	注入率 g/m ³	使用量 kg																																																																																																			
	令和4年 4月	2,155	7.9	115,182	0.8	1,537																																																																																																			
	5月	1,688	5.7	106,015	0.7	5																																																																																																			
	6月	1,011	3.6	125,330	0.9	8,647																																																																																																			
	7月	1,150	3.9	172,945	1.1	2,944																																																																																																			
	8月	1,896	6.4	167,435	1.1	26,089																																																																																																			
	9月	938	3.3	166,001	1.1	1,511																																																																																																			
	10月	1,512	4.4	172,122	1.2	5,382																																																																																																			
	11月	917	3.0	152,417	1.1	14,938																																																																																																			
	12月	770	2.6	132,315	0.9	1,018																																																																																																			
	令和5年 1月	507	1.7	142,464	1.0	48,098																																																																																																			
	2月	406	1.5	114,553	0.8	8,714																																																																																																			
3月	2,573	7.6	120,515	0.8	6,098																																																																																																				
合計	15,520		1,687,295		124,981																																																																																																				
月平均	1,293	4.7	140,608	0.9	10,415																																																																																																				
日平均	43		4,623		342																																																																																																				
備考	p.58 12 薬品使用量 総計値 (札幌水道)																																																																																																								

項目		ポリ塩化アルミニウム		消石灰		次亜塩素酸ナトリウム		活性炭
		使用量 kg	注入率 g/m ³	使用量 kg	注入率 g/m ³	使用量 kg	注入率 g/m ³	使用量 kg
(誤)	令和4年 4月	410,686	31.6	35,619	2.7	93,784	27.9	1,481
	5月	335,491	25.2	27,420	2.1	84,575	25.4	0
	6月	311,959	24.1	23,301	1.8	101,182	30.2	7,626
	7月	340,970	25.1	22,971	1.7	141,371	41.6	1,887
	8月	586,947	44.1	44,252	3.3	135,099	40.6	21,295
	9月	421,915	33.0	23,616	1.8	134,606	40.8	0
	10月	465,600	32.7	22,957	1.6	149,240	42.0	4,559
	11月	431,863	32.6	22,703	1.7	129,229	37.7	12,329
	12月	271,902	20.4	11,395	0.9	107,508	32.2	796
	令和5年 1月	332,124	25.1	20,871	1.6	116,678	35.1	40,421
	2月	229,703	19.0	15,850	1.3	93,026	27.5	8,044
	3月	345,703	26.1	21,746	1.6	97,237	29.2	5,341
合計	4,484,863		292,701		1,383,535		103,779	
月平均	373,739	28.3	24,392	1.8	115,295	34.2	8,648	
日平均	12,287		802		3,791		284	

項目		ポリ塩化アルミニウム		消石灰		次亜塩素酸ナトリウム		活性炭
		使用量 kg	注入率 g/m ³	使用量 kg	注入率 g/m ³	使用量 kg	注入率 g/m ³	使用量 kg
(正)	令和4年 4月	410,686	31.3	35,619	2.7	93,784	0.9	1,481
	5月	335,491	24.9	27,420	2.0	84,575	0.8	0
	6月	311,959	23.8	23,301	1.8	101,182	1.0	7,626
	7月	340,970	24.8	22,971	1.7	141,371	1.3	1,887
	8月	586,947	43.7	44,252	3.3	135,099	1.3	21,295
	9月	421,915	32.7	23,616	1.8	134,606	1.4	0
	10月	465,600	32.4	22,957	1.6	149,240	1.4	4,559
	11月	431,863	32.3	22,703	1.7	129,229	1.3	12,329
	12月	271,902	20.2	11,395	0.8	107,508	1.0	796
	令和5年 1月	332,124	24.7	20,871	1.6	116,678	1.1	40,421
	2月	229,703	18.7	15,850	1.3	93,026	1.0	8,044
	3月	345,703	25.7	21,746	1.6	97,237	0.9	5,341
合計	4,484,863		292,701		1,383,535		103,779	
月平均	373,739	28.0	24,392	1.8	115,295	1.1	8,648	
日平均	12,287		802		3,791		284	

備考	p.59 12 薬品使用量 白川浄水場
----	---------------------

白川浄水場									
項目 年月	ろ過池洗浄		ろ過水量及び速度			洗浄水量 ろ過水量 %	ろ過平均 持続時間 時:分	平均 損失水頭 m	
	回数	水量 m ³	月 m ³	一日平均 m ³	平均ろ速 m/D				
令和4年 4月	365	238,103	436,762	436,762	117.1	54.5	68:08	0.96	
5月	368	243,542	433,362	433,362	115.9	56.2	70:11	1.03	
6月	379	257,423	435,616	435,616	116.9	59.1	66:13	1.26	
7月	400	275,769	441,920	441,920	116.7	62.4	64:00	1.14	
8月	397	271,668	432,604	432,604	116.5	62.8	65:12	0.83	
9月	383	263,405	429,095	429,095	115.5	61.4	65:16	0.87	
10月	532	365,118	462,128	462,128	122.3	79.0	48:48	0.77	
11月	455	307,376	445,151	445,151	117.9	69.0	56:09	0.83	
12月	375	246,176	433,645	433,645	116.1	56.8	67:41	1.01	
令和5年 1月	384	242,558	432,602	432,602	115.4	56.1	67:07	0.95	
2月	353	222,523	439,036	439,036	116.9	50.7	65:52	1.07	
3月	401	251,985	433,067	433,067	115.7	58.2	64:09	1.04	
合計	4,792	3,185,646	5,254,988						
月平均	399	265,471	437,916		117.1	60.6	63:25	0.97	
日平均	13	8,728	14,397						

(誤)

白川浄水場									
項目 年月	ろ過池洗浄		ろ過水量及び速度			洗浄水量 ろ過水量 %	ろ過平均 持続時間 時:分	平均 損失水頭 m	
	回数	水量 m ³	月 m ³	一日平均 m ³	平均ろ速 m/D				
令和4年 4月	365	238,103	13,102,847	436,762	117.1	1.8	68:08	0.96	
5月	368	243,542	13,434,214	433,362	115.9	1.8	70:11	1.03	
6月	379	257,423	13,068,466	435,616	116.9	2.0	66:13	1.26	
7月	400	275,769	13,699,505	441,920	116.7	2.0	64:00	1.14	
8月	397	271,668	13,410,734	432,604	116.5	2.0	65:12	0.83	
9月	383	263,405	12,872,839	429,095	115.5	2.0	65:16	0.87	
10月	532	365,118	14,325,956	462,128	122.3	2.5	48:48	0.77	
11月	455	307,376	13,354,519	445,151	117.9	2.3	56:09	0.83	
12月	375	246,176	13,442,984	433,645	116.1	1.8	67:41	1.01	
令和5年 1月	384	242,558	13,410,657	432,602	115.4	1.8	67:07	0.95	
2月	353	222,523	12,293,002	439,036	116.9	1.8	65:52	1.07	
3月	401	251,985	13,425,091	433,067	115.7	1.9	64:09	1.04	
合計	4,792	3,185,646	159,840,814						
月平均	399	265,471	13,320,068		117.1	2.0	63:25	0.97	
日平均	13	8,728	437,920						

(正)

備考	p.62 13 ろ過池使用状況 白川浄水場
----	-----------------------

(誤)	<table border="1" data-bbox="491 360 1283 752"> <thead> <tr> <th colspan="2">浄水場名</th> </tr> </thead> <tbody> <tr> <td>藻岩浄水場</td> <td>能力 155,000m³/日</td> </tr> <tr> <td>白川浄水場</td> <td>能力 650,000m³/日</td> </tr> <tr> <td>定山溪浄水場</td> <td>能力 9,000m³/日</td> </tr> <tr> <td>西野浄水場</td> <td>能力 15,600m³/日</td> </tr> </tbody> </table>	浄水場名		藻岩浄水場	能力 155,000m ³ /日	白川浄水場	能力 650,000m ³ /日	定山溪浄水場	能力 9,000m ³ /日	西野浄水場	能力 15,600m ³ /日
浄水場名											
藻岩浄水場	能力 155,000m ³ /日										
白川浄水場	能力 650,000m ³ /日										
定山溪浄水場	能力 9,000m ³ /日										
西野浄水場	能力 15,600m ³ /日										
(正)	<table border="1" data-bbox="491 1010 1283 1402"> <thead> <tr> <th colspan="2">浄水場名</th> </tr> </thead> <tbody> <tr> <td>藻岩浄水場</td> <td>能力 129,000m³/日</td> </tr> <tr> <td>白川浄水場</td> <td>能力 542,000m³/日</td> </tr> <tr> <td>定山溪浄水場</td> <td>能力 8,400m³/日</td> </tr> <tr> <td>西野浄水場</td> <td>能力 14,600m³/日</td> </tr> </tbody> </table>	浄水場名		藻岩浄水場	能力 129,000m ³ /日	白川浄水場	能力 542,000m ³ /日	定山溪浄水場	能力 8,400m ³ /日	西野浄水場	能力 14,600m ³ /日
浄水場名											
藻岩浄水場	能力 129,000m ³ /日										
白川浄水場	能力 542,000m ³ /日										
定山溪浄水場	能力 8,400m ³ /日										
西野浄水場	能力 14,600m ³ /日										
備考	<p>p.215 1 浄水場給水区域図</p> <p>p.216 2 給水区域及び施設位置図</p> <p>各浄水場の能力</p>										

(誤)	配水施設（稼働数）			
		全数	配水センター管理	浄水場管理
	ポンプ場・配水池併施設	17	17	0
	単独ポンプ場	22	21	◆1
	単独配水池	26	22	◆4
(正)	配水施設（稼働数）			
		全数	配水センター管理	浄水場管理
	ポンプ場・配水池併施設	14	14	0
	単独ポンプ場	24	23	◆1
	単独配水池	28	24	◆4
備考	p.217 3 配水系統図			